



**OPERATING MANUAL ADDENDUM**

**for the**

**POWER DISTRIBUTION UNIT (PDU)**

**MODEL PDU 2000-6**

**ELGAR CORPORATION  
9250 Brown Deer Road  
San Diego, CA 92121**

**Model PDU 2000-6  
Operation**

**© 1998 ELGAR CORPORATION**

**This document contains information proprietary to ELGAR Corporation. The information contained herein is not to be duplicated or transferred in any manner without prior written permission from ELGAR Corporation.**

**Document No. M152461-01 Rev. A**

**September 17, 1998**

## **1.1 INTRODUCTION**

The PDU 2000-6 is a special modification of the PDU 2000 that provides an extended operating temperature range.

## **1.2 GENERAL**

Installation and operation of the PDU 2000-6 is the same as presented in the PDU 2000 Operation Manual except with regard to the temperature thresholds: The Overtemperature Threshold is 51°C (124°F),  $\pm 1^\circ$ ; the Overtemperature Shutdown Threshold is 56°C (133°F),  $\pm 1^\circ$ .